

SUMMARY OF CHANGES - DCPM Revisions 2008 to 2010

Revision	Date	Section	Description
1	Apr-10	20.07.01.00	Added Contaminated Soils Investigation and Reporting
2	Apr-10	20.10.00.00	Clarified Deadline to Submit Corrosion Evaluation
3	Apr-10	20.10.03.00	Added Conditions for DIP Joint Bonding
4	Apr-10	20.11.02.00	Added "Exterior Applications" to SP-10 Cleaning Criteria
5	Apr-10	20.11.02.00	Changed SP-6 to SP-10
6	Apr-10	30.02.02.00	Added HDPE Pipe Cell Classification "ASTM D3350" and HDPE Fitting Specification "ASTM F1055"
7	Apr-10	30.02.03.00	Sewer Mains with 5.5' to 8.0' Feet of Cover Must be Insulated.
8	Apr-10	30.02.05.07	Clarified Locking Manhole Frames are Watertight
9	Apr-10	30.02.06.00	Moved Restraint Requirement to the Standard Details
10	Apr-10	30.03.03.02	Conditional Exception to Permit Cast Iron Sewer Service Extension or Repair
11	Apr-10	30.03.03.03	Polyethylene encasement and restrained fittings required on sewer service cleanouts.
12	Apr-10	30.03.06.00	Changed Bedding Limit From Springline to 6" Above Pipe
13	Apr-10	30.03.07.00	Allows Repair (<10') of Cast Iron and Asbestos Cement Services With Cast Iron Pipe. (Previously required Ductile Iron Pipe)
14	Apr-10	30.03.18.00	Changed From Wrap-Around to Romac Style CB Sewer Saddle
15	Apr-10	40.02.03.00	Added Engineered Contaminated Soils Analysis
16	Apr-10	40.02.03.00	Added HDPE Pipe Cell Classification "ASTM D3350" and HDPE Fitting Specification "ASTM F1055"
17	Apr-10	40.02.04.03	Hydrant Bollards only Used in Parking Areas.
18	Apr-10	40.02.10.00	Fire Lines Shall be Restrained From the Main to the Property Line.
19	Apr-10	40.02.11.00	Tie Rods are Not Acceptable Pipe Restraints.
20	Apr-10	40.03.10.01	Waiver of Engineered Plans if 10 Feet or Less.
21	Apr-10	40.03.16.00	Added Backflow Prevention Assembly and Bleeder to Water Meters.
22	Apr-10	40.03.18.00	Eliminated Option for AWWU to Perform Live Taps for 2" or Smaller Water Services.
23	Apr-10	40.03.19.01	Clarified Keybox Components.
24	Apr-10	40.03.19.02	Deleted "Copper Wire" to Connect Operating Rod to Curb Stop. 40.03.20 Specifies 9/64" X 4" Brass Cotter Pin.
25	Apr-10	40.03.21.00	Solid Copper Retainer Disc (plug) Required on Abandoned 2" Corporation Stops.

26	Apr-10	40.05.12.00	Clarified Type of Facilities Requiring SCADA.
27	Apr-10	60.03.01.00	Replaced previous drawing templates in this section with new templates. CAD files are available on-line at www.awwu.biz .
28	Apr-10	60.03.03.00	Added new section for private system projects. CAD files are available on-line at www.awwu.biz .
29	Apr-10	70.04.00.00	Clarified AWWU I&E Specifications Format.
30	Apr-10	70.04.10.00	Specified "D-153 Duplex Level Controller" Wetwell Level Transmitter.
31	Apr-10	70.04.13.00	Specified PVC Coated Conduit and Fittings in Corrosive Environments.
32	Apr-10	70.05.00.00	Updated AWWU Revised MASS Details (20-19, 50-1 (new), 50-7, 50-10 (new), 50-11 (new), 50-13, 50-14, 50-16, 50-18 (new), 50-19, 50-20, 50-21, 60-1, 60-2 (new), 60-7, and 60-12)
33	Apr-10	70.06.00.00	Updated HDPE drawing details and notes. Major changes to copper service pipe coating specifications in HDPE mainline/highly corrosive applications.